

## *Appendix C*

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

**Route or Travel**

<u>Is there a route of travel that does not require the use of stairs?</u>	<u>YES</u>
<u>is the route of travel stable, firm and slip-resistant?</u>	<u>YES</u>
<u>Is the route at least 36 inches wide?</u>	<u>YES</u>
<u>Can all objects protruding into the circulation paths be detected by a person with a visual disability?</u>	<u>YES</u>
<u>Do curbs on the route have curb cuts at drives, parking, and drop-offs?</u>	<u>YES</u>

**Ramps**

<u>Are the Slopes of ramps no greater than 1:12?</u>	<u>N/A</u>
<u>Do all ramps longer than 6 feet have railings on both sides?</u>	<u>N/A</u>
<u>Are railings sturdy, and between 34 and 38 inches high?</u>	<u>N/A</u>
<u>Is the width between railings or curbs at least 38 inches?</u>	<u>N/A</u>
<u>Are ramps non-slip</u>	<u>N/A</u>
<u>Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?</u>	<u>N/A</u>
<u>Does the ramp rise no more than 30 inches between landings</u>	<u>N/A</u>

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

**Parking & Drop-Off**

Are an adequate number of parking spaces available?	N/A
Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?	N/A
Are the access aisles part of the accessible route to the accessible entrance?	N/A
Are the accessible spaces closest to the accessible entrance?	N/A
Are accessible spaces marked with the International Symbol of Accessibility?	N/A
Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?	N/A

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?	N/A
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?	N/A
Can the alternate accessible entrance be used independently?	N/A
Does the entrance door have at least 32 inches clear opening?	YES
Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?	YES
Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?	YES
If provided, are carpeting or mats a maximum of 1/2 inch high?	YES

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

Is the door handle no higher than 48 inches and operable with a closed fist? **YES**

Can doors be opened without too much force? **YES**

If the door has a closer, does it take at least 3 seconds to close? **YES**

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? **YES**

Are all public spaces on an accessible route of travel? **YES**

Is the accessible route to all public spaces at least 36 inches wide? **YES**

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? **YES**

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? **YES**

On the pull side of doors, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair can open the door? **YES**

Can doors be opened without too much force? **YES**

Are door handles 48 inches high or less and operable with a closed fist? **YES**

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **YES**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **YES**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **YES**

Mounted on wall adjacent to latch side of door, or as close as possible **NO**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **NO**

Brailled text of the same information? **NO**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

**Controls**

Are all controls that are available for use by the public located at an accessible height? **YES**

Are they opeable with a closed fist? **NO**

**Stairs**

Do treads have a non-slip surface? **NO**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **YES**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

Is there tactile signage identifying rest rooms **YES**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **YES**

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

Are doors equipped with accessible handles, 48 inches high or less? **YES**

---

Can doors be opened easily? **YES**

---

Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? **YES**

---

Is there a 36 inch wide path to all fixtures? **YES**

---

**Stalls**

Is the stall door operable with a closed fist, inside and out? **NO**

---

Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall? **NO**

---

In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet? **NO**

---

Is the toilet seat 17 to 19 inches high? **YES**

---

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front? **YES**

---

Is the lavatory rim no higher than 34 inches **YES**

---

Is there at least 29 inches from the floor to the bottom of the lavatory apron? **YES**

---

Can the faucet be operated with one closed fist? **YES**

---

**ADA**  
**Self Evaluation**

**Facility: Fire Station**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? **YES**

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? **NO**

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? **N/A**

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? **N/A**

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? **N/A**

---

Is each water fountain cane-detectable? **N/A**

---

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

**Route or Travel**

Is there a route of travel that does not require the use of stairs?	YES
Is the route of travel stable, firm and slip-resistant?	YES
Is the route at least 36 inches wide?	YES
Can all objects protruding into the circulation paths be detected by a person with a visual disability?	YES
Do curbs on the route have curb cuts at drives, parking, and drop-offs?	YES

**Ramps**

Are the Slopes of ramps no greater than 1:12?	YES
Do all ramps longer than 6 feet have railings on both sides?	N/A
Are railings sturdy, and between 34 and 38 inches high?	N/A
Is the width between railings or curbs at least 38 inches?	YES
Are ramps non-slip	NO
Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?	N/A
Does the ramp rise no more than 30 inches between landings	N/A

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

**Parking & Drop-Off**

Are an adequate number of parking spaces available? YES

Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van? YES

Are the access aisles part of the accessible route to the accessible entrance? YES

Are the accessible spaces closest to the accessible entrance? YES

Are accessible spaces marked with the International Symbol of Accessibility? NO

Is there an enforcement procedure to ensure that accessible parking is used only by those who need it? YES

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance? Yes, ramp

Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance? NO

Can the alternate accessible entrance be used independently? YES

Does the entrance door have at least 32 inches clear opening? YES

Is there at least 18 inches of clear wall space on the pull side of the door, next to handle? YES

Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high? YES

If provided, are carpeting or mats a maximum of 1/2 inch high? YES

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

Is the door handle no higher than 48 inches and operable with a closed fist? NO

Can doors be opened without too much force? YES

If the door has a closer, does it take at least 3 seconds to close? YES

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? YES

Are all public spaces on an accessible route of travel? YES

Is the accessible route to all public spaces at least 36 inches wide? NO

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? YES

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? YES

On the pull side of doors, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair can open the door? YES

Can doors be opened without too much force? YES

Are door handles 48 inches high or less and operable with a closed fist? YES

**ADA**  
**Self Evaluation**

**Facility:** *Drinking Water Plant*

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **YES**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **NO**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **N/A**

Mounted on wall adjacent to latch side of door, or as close as possible **N/A**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **N/A**

Brailled text of the same information? **N/A**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

**Controls**

Are all controls that are available for use by the public located at an accessible height? N/A

---

Are they opeable with a closed fist? N/A

---

**Stairs**

Do treads have a non-slip surface? N/A

---

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? N/A

---

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? N/A

---

Are there signs at inaccessible rest rooms that give directions to acceisble ones? N/A

---

Is there tactile signage identifying rest rooms N/A

---

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? N/A

---

Is the doorway at least 32 inces clear? N/A

---

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

Are doors equipped with accessible handles, 48 inches high or less? N/A

---

Can doors be opened easily? N/A

---

Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? N/A

---

Is there a 36 inch wide path to all fixtures? N/A

---

**Stalls**

Is the stall door operable with a closed fist, inside and out? N/A

---

Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall? N/A

---

In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet? N/A

---

Is the toilet seat 17 to 19 inches high? N/A

---

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front? N/A

---

Is the lavatory rim no higher than 34 inches N/A

---

Is there at least 29 inches from the floor to the bottom of the lavatory apron? N/A

---

Can the faucet be operated with one closed fist? N/A

---

**ADA**  
**Self Evaluation**

**Facility: Drinking Water Plant**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? N/A

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? N/A

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? N/A

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? N/A

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? N/A

---

Is each water fountain cane-detectable? N/A

---

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

**Route or Travel**

Is there a route of travel that does not require the use of stairs? YES

Is the route of travel stable, firm and slip-resistant? YES

Is the route at least 36 inches wide? YES

Can all objects protruding into the circulation paths be detected by a person with a visual disability? YES

Do curbs on the route have curb cuts at drives, parking, and drop-offs? N/A

**Ramps**

Are the Slopes of ramps no greater than 1:12? N/A

Do all ramps longer than 6 feet have railings on both sides? N/A

Are railings sturdy, and between 34 and 38 inches high? N/A

Is the width between railings or curbs at least 38 inches? N/A

Are ramps non-slip? N/A

Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks? N/A

Does the ramp rise no more than 30 inches between landings? N/A

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

**Parking & Drop-Off**

Are an adequate number of parking spaces available? N/A

Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van? N/A

Are the access aisles part of the accessible route to the accessible entrance? N/A

Are the accessible spaces closest to the accessible entrance? N/A

Are accessible spaces marked with the International Symbol of Accessibility? N/A

Is there an enforcement procedure to ensure that accessible parking is used only by those who need it? N/A

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance? YES

Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance? NO

Can the alternate accessible entrance be used independently? YES

Does the entrance door have at least 32 inches clear opening? YES

Is there at least 18 inches of clear wall space on the pull side of the door, next to handle? YES

Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high? NO

If provided, are carpeting or mats a maximum of 1/2 inch high? N/A

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

Is the door handle no higher than 48 inches and operable with a closed fist? NO

Can doors be opened without too much force? N/A

If the door has a closer, does it take at least 3 seconds to close? N/A

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? YES

Are all public spaces on an accessible route of travel? YES

Is the accessible route to all public spaces at least 36 inches wide? YES

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? YES

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? YES

On the pull side of doors, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair can open the door? YES

Can doors be opened without too much force? YES

Are door handles 48 inches high or less and operable with a closed fist? NO

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **NO**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **N/A**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **N/A**

Mounted on wall adjacent to latch side of door, or as close as possible **N/A**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **N/A**

Brailled text of the same information? **N/A**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility:** *Electric Department*

**Controls**

Are all controls that are available for use by the public located at an accessible height? **N/A**

Are they opeable with a closed fist? **N/A**

**Stairs**

Do treads have a non-slip surface? **NO**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **NO**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

Is there tactile signage identifying rest rooms **NO**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **NO**

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

Are doors equipped with accessible handles, 48 inches high or less?	YES
Can doors be opened easily?	YES
Does the entry configuration provide adequate maneuvering space for a person using a wheelchair?	YES
Is there a 36 inch wide path to all fixtures?	NO

**Stalls**

Is the stall door operable with a closed fist, inside and out?	N/A
Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall?	NO
In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet?	NO
Is the toilet seat 17 to 19 inches high?	NO

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front?	NO
Is the lavatory rim no higher than 34 inches	NO
Is there at least 29 inches from the floor to the bottom of the lavatory apron?	N/A
Can the faucet be operated with one closed fist?	NO

**ADA**  
**Self Evaluation**

**Facility: Electric Department**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? **NO**

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? **N/A**

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? **N/A**

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? **N/A**

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? **N/A**

---

Is each water fountain cane-detectable? **N/A**

---

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

**Route or Travel**

Is there a route of travel that does not require the use of stairs?	YES
Is the route of travel stable, firm and slip-resistant?	YES
Is the route at least 36 inches wide?	YES
Can all objects protruding into the circulation paths be detected by a person with a visual disability?	YES
Do curbs on the route have curb cuts at drives, parking, and drop-offs?	YES

**Ramps**

Are the Slopes of ramps no greater than 1:12?	N/A
Do all ramps longer than 6 feet have railings on both sides?	N/A
Are railings sturdy, and between 34 and 38 inches high?	N/A
Is the width between railings or curbs at least 38 inches?	N/A
Are ramps non-slip	N/A
Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?	N/A
Does the ramp rise no more than 30 inches between landings	N/A

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

**Parking & Drop-Off**

Are an adequate number of parking spaces available?	YES
Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?	YES
Are the access aisles part of the accessible route to the accessible entrance?	NO
Are the accessible spaces closest to the accessible entrance?	YES
Are accessible spaces marked with the International Symbol of Accessibility?	NO
Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?	YES

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?	N/A
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?	NO
Can the alternate accessible entrance be used independently?	YES
Does the entrance door have at least 32 inches clear opening?	YES
Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?	YES
Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?	NO
If provided, are carpeting or mats a maximum of 1/2 inch high?	N/A

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

Is the door handle no higher than 48 inches and operable with a closed fist? **N/A**

Can doors be opened without too much force? **YES**

If the door has a closer, does it take at least 3 seconds to close? **N/A**

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? **YES**

Are all public spaces on an accessible route of travel? **NO**

Is the accessible route to all public spaces at least 36 inches wide? **YES**

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? **YES**

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? **YES**

On the pull side of doors, next to the handle, is there at least 18 inches of ? clear wall space so that a person using a wheelchair can open the door **YES**

Can doors be opened without too much force? **YES**

Are door handles 48 inches high or less and operable with a closed fist? **NO**

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **YES**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **NO**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **YES**

Mounted on wall adjacent to latch side of door, or as close as possible **NO**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **NO**

Brailled text of the same information? **NO**

If pictogram is used, it must be accompanied by raised characters and braille? **NO**

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

**Controls**

Are all controls that are available for use by the public located at an accessible height? **N/A**

---

Are they opeable with a closed fist? **N/A**

---

**Stairs**

Do treads have a non-slip surface? **NO**

---

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **NO**

---

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

---

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

---

Is there tactile signage identifying rest rooms **YES**

---

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

---

Is the doorway at least 32 inces clear? **YES**

---

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

Are doors equipped with accessible handles, 48 inches high or less? YES

Can doors be opened easily? YES

Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? YES

Is there a 36 inch wide path to all fixtures? YES

**Stalls**

Is the stall door operable with a closed fist, inside and out? NO

Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall? NO

In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet? NO

Is the toilet seat 17 to 19 inches high? YES

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front? YES

Is the lavatory rim no higher than 34 inches? YES

Is there at least 29 inches from the floor to the bottom of the lavatory apron? NO

Can the faucet be operated with one closed fist? YES

**ADA**  
**Self Evaluation**

**Facility: Hub Park Pool**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? YES

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? N/A

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? N/A

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? N/A

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? N/A

---

Is each water fountain cane-detectable? N/A

---

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

**Route or Travel**

Is there a route of travel that does not require the use of stairs? **YES**

Is the route of travel stable, firm and slip-resistant? **YES**

Is the route at least 36 inches wide? **YES**

Can all objects protruding into the circulation paths be detected by a person with a visual disability? **YES**

Do curbs on the route have curb cuts at drives, parking, and drop-offs? **YES**

**Ramps**

Are the Slopes of ramps no greater than 1:12? **YES**

Do all ramps longer than 6 feet have railings on both sides? **NO**

Are railings sturdy, and between 34 and 38 inches high? **N/A**

Is the width between railings or curbs at least 38 inches? **N/A**

Are ramps non-slip **YES**

Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks? **N/A**

Does the ramp rise no more than 30 inches between landings **N/A**

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

**Parking & Drop-Off**

<u>Are an adequate number of parking spaces available?</u>	<u>N/A</u>
<u>Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?</u>	<u>N/A</u>
<u>Are the access aisles part of the accessible route to the accessible entrance?</u>	<u>N/A</u>
<u>Are the accessible spaces closest to the accessible entrance?</u>	<u>N/A</u>
<u>Are accessible spaces marked with the International Symbol of Accessibility?</u>	<u>N/A</u>
<u>Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?</u>	<u>N/A</u>

**Entrance**

<u>If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?</u>	<u>YES</u>
<u>Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?</u>	<u>NO</u>
<u>Can the alternate accessible entrance be used independently?</u>	<u>NO</u>
<u>Does the entrance door have at least 32 inches clear opening?</u>	<u>YES</u>
<u>Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?</u>	<u>YES</u>
<u>Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?</u>	<u>YES</u>
<u>If provided, are carpeting or mats a maximum of 1/2 inch high?</u>	<u>N/A</u>

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

<u>Is the door handle no higher than 48 inches and operable with a closed fist?</u>	<u>YES</u>
<u>Can doors be opened without too much force?</u>	<u>YES</u>
<u>If the door has a closer, does it take at least 3 seconds to close?</u>	<u>N/A</u>

**Horizontal Circulation**

<u>Does the accessible entrance provide direct access to the main floor?</u>	<u>YES</u>
<u>Are all public spaces on an accessible route of travel?</u>	<u>YES</u>
<u>Is the accessible route to all public spaces at least 36 inches wide?</u>	<u>YES</u>
<u>is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction?</u>	<u>YES</u>

**Doors**

<u>Do doors into public spaces have at least a 32 inch clear opening?</u>	<u>N/A</u>
<u>On the pull side of doors, next to the handle, is there at least 18 inches of ? clear wall space so that a person using a wheelchair can open the door</u>	<u>N/A</u>
<u>Can doors be opened without too much force?</u>	<u>N/A</u>
<u>Are door handles 48 inches high or less and operable with a closed fist?</u>	<u>N/A</u>

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **YES**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **YES**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **N/A**

Mounted on wall adjacent to latch side of door, or as close as possible **N/A**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **N/A**

Brailled text of the same information? **N/A**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

**Controls**

Are all controls that are available for use by the public located at an accessible height? **YES**

Are they opeable with a closed fist? **YES**

**Stairs**

Do treads have a non-slip surface? **NO**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **NO**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

Is there tactile signage identifying rest rooms **NO**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **YES**

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

Are doors equipped with accessible handles, 48 inches high or less? **NO**

Can doors be opened easily? **YES**

Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? **NO**

Is there a 36 inch wide path to all fixtures? **YES**

**Stalls**

Is the stall door operable with a closed fist, inside and out? **YES**

Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall? **YES**

In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet? **YES**

Is the toilet seat 17 to 19 inches high? **YES**

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front? **YES**

Is the lavatory rim no higher than 34 inches **YES**

Is there at least 29 inches from the floor to the bottom of the lavatory apron? **YES**

Can the faucet be operated with one closed fist? **YES**

**ADA**  
**Self Evaluation**

**Facility: Scout Cabin**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? YES

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? NO

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? N/A

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? N/A

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? N/A

---

Is each water fountain cane-detectable? N/A

---

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

**Route or Travel**

Is there a route of travel that does not require the use of stairs?	<b>YES</b>
Is the route of travel stable, firm and slip-resistant?	<b>NO</b>
Is the route at least 36 inches wide?	<b>YES</b>
Can all objects protruding into the circulation paths be detected by a person with a visual disability?	<b>YES</b>
Do curbs on the route have curb cuts at drives, parking, and drop-offs?	<b>NO</b>

**Ramps**

Are the Slopes of ramps no greater than 1:12?	<b>N/A</b>
Do all ramps longer than 6 feet have railings on both sides?	<b>N/A</b>
Are railings sturdy, and between 34 and 38 inches high?	<b>N/A</b>
Is the width between railings or curbs at least 38 inches?	<b>N/A</b>
Are ramps non-slip	<b>N/A</b>
Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?	<b>N/A</b>
Does the ramp rise no more than 30 inches between landings	<b>N/A</b>

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

**Parking & Drop-Off**

Are an adequate number of parking spaces available?	N/A
Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?	N/A
Are the access aisles part of the accessible route to the accessible entrance?	N/A
Are the accessible spaces closest to the accessible entrance?	N/A
Are accessible spaces marked with the International Symbol of Accessibility?	N/A
Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?	N/A

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?	NO
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?	NO
Can the alternate accessible entrance be used independently?	NO
Does the entrance door have at least 32 inches clear opening?	YES
Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?	YES
Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?	NO
If provided, are carpeting or mats a maximum of 1/2 inch high?	N/A

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

Is the door handle no higher than 48 inches and operable with a closed fist? **YES**

Can doors be opened without too much force? **YES**

If the door has a closer, does it take at least 3 seconds to close? **N/A**

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? **N/A**

Are all public spaces on an accessible route of travel? **YES**

Is the accessible route to all public spaces at least 36 inches wide? **NO**

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? **YES**

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? **N/A**

On the pull side of doors, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair can open the door? **N/A**

Can doors be opened without too much force? **N/A**

Are door handles 48 inches high or less and operable with a closed fist? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **NO**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **NO**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **N/A**

Mounted on wall adjacent to latch side of door, or as close as possible **N/A**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **N/A**

Brailled text of the same information? **N/A**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

**Controls**

Are all controls that are available for use by the public located at an accessible height? **YES**

Are they opeable with a closed fist? **YES**

**Stairs**

Do treads have a non-slip surface? **N/A**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **N/A**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

Is there tactile signage identifying rest rooms **YES**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **YES**

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

Are doors equipped with accessible handles, 48 inches high or less?	<b>NO</b>
Can doors be opened easily?	<b>YES</b>
Does the entry configuration provide adequate maneuvering space for a person using a wheelchair?	<b>YES</b>
Is there a 36 inch wide path to all fixtures?	<b>YES</b>

**Stalls**

Is the stall door operable with a closed fist, inside and out?	<b>YES</b>
Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall?	<b>NO</b>
In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet?	<b>NO</b>
Is the toilet seat 17 to 19 inches high?	<b>Yes</b>

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front?	<b>NO</b>
Is the lavatory rim no higher than 34 inches	<b>NO</b>
Is there at least 29 inches from the floor to the bottom of the lavatory apron?	<b>YES</b>
Can the faucet be operated with one closed fist?	<b>YES</b>

**ADA**  
**Self Evaluation**

**Facility: Sterling Park**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? **YES**

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? **N/A**

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? **NO**

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? **NO**

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? **YES**

---

Is each water fountain cane-detectable? **YES**

---

ADA  
Self Evaluation

**Facility:** *Town Hall*

**Route or Travel**

<u>Is there a route of travel that does not require the use of stairs?</u>	<u>YES</u>
<u>is the route of travel stable, firm and slip-resistant?</u>	<u>YES</u>
<u>Is the route at least 36 inches wide?</u>	<u>YES</u>
<u>Can all objects protruding into the circulation paths be detected by a person with a visual disability?</u>	<u>YES</u>
<u>Do curbs on the route have curb cuts at drives, parking, and drop-offs?</u>	<u>YES</u>

**Ramps**

<u>Are the Slopes of ramps no greather than 1:12?</u>	<u>YES</u>
<u>Do all ramps longer than 6 feet have railings on both sides?</u>	<u>NO</u>
<u>Are railings sturdy, and between 34 and 38 inches high?</u>	<u>YES</u>
<u>Ist he width between railings or curbs at least 38 inches?</u>	<u>YES</u>
<u>Are ramps non-slip</u>	<u>NO</u>
<u>Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?</u>	<u>YES</u>
<u>Does the ramp rise no more than 30 inces between landings</u>	<u>YES</u>

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

**Parking & Drop-Off**

<u>Are an adequate number of parking spaces available?</u>	<u>YES</u>
<u>Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?</u>	<u>YES</u>
<u>Are the access aisles part of the accessible route to the accessible entrance?</u>	<u>YES</u>
<u>Are the accessible spaces closest to the accessible entrance?</u>	<u>YES</u>
<u>Are accessible spaces marked with the International Symbol of Accessibility?</u>	<u>YES</u>
<u>Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?</u>	<u>YES</u>

**Entrance**

<u>If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?</u>	<u>YES</u>
<u>Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?</u>	<u>N/A</u>
<u>Can the alternate accessible entrance be used independently?</u>	<u>YES</u>
<u>Does the entrance door have at least 32 inches clear opening?</u>	<u>YES</u>
<u>Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?</u>	<u>YES</u>
<u>Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?</u>	<u>YES</u>
<u>If provided, are carpeting or mats a maximum of 1/2 inch high?</u>	<u>YES</u>

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

Is the door handle no higher than 48 inches and operable with a closed fist? **YES**

Can doors be opened without too much force? **YES**

If the door has a closer, does it take at least 3 seconds to close? **YES**

**Horizontal Circulation**

Does the accessible entrance provide direct access to the main floor? **YES**

Are all public spaces on an accessible route of travel? **YES**

Is the accessible route to all public spaces at least 36 inches wide? **YES**

is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction? **YES**

**Doors**

Do doors into public spaces have at least a 32 inch clear opening? **YES**

On the pull side of doors, next to the handle, is there at least 18 inches of clear wall space so that a person using a wheelchair can open the door? **YES**

Can doors be opened without too much force? **YES**

Are door handles 48 inches high or less and operable with a closed fist? **YES**

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **YES**

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **YES**

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **NO**

Mounted on wall adjacent to latch side of door, or as close as possible **NO**

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **NO**

Brailled text of the same information? **NO**

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

**Controls**

Are all controls that are available for use by the public located at an accessible height? **YES**

Are they opeable with a closed fist? **YES**

**Stairs**

Do treads have a non-slip surface? **NO**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **NO**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **YES**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **N/A**

Is there tactile signage identifying rest rooms **YES**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **YES**

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

Are doors equipped with accessible handles, 48 inches high or less?	YES
Can doors be opened easily?	YES
Does the entry configuration provide adequate maneuvering space for a person using a wheelchair?	YES
Is there a 36 inch wide path to all fixtures?	YES

**Stalls**

Is the stall door operable with a closed fist, inside and out?	YES
Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall?	YES
In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet?	YES
Is the toilet seat 17 to 19 inches high?	YES

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front?	YES
Is the lavatory rim no higher than 34 inches	YES
Is there at least 29 inches from the floor to the bottom of the lavatory apron?	YES
Can the faucet be operated with one closed fist?	YES

**ADA**  
**Self Evaluation**

**Facility: Town Hall**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? **YES**

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? **YES**

---

**Drinking Fountains**

Is there at least one fountain with clear floor space of at least 30 by 48 inches in front? **YES**

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? **YES**

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? **YES**

---

Is each water fountain cane-detectable? **YES**

---

**ADA**  
**Self Evaluation**

**Facility:** *Wastewater Treatment Plant*

**Route or Travel**

<u>Is there a route of travel that does not require the use of stairs?</u>	<u>YES</u>
<u>is the route of travel stable, firm and slip-resistant?</u>	<u>NO</u>
<u>Is the route at least 36 inches wide?</u>	<u>N/A</u>
<u>Can all objects protruding into the circulation paths be detected by a person with a visual disability?</u>	<u>N/A</u>
<u>Do curbs on the route have curb cuts at drives, parking, and drop-offs?</u>	<u>N/A</u>

**Ramps**

<u>Are the Slopes of ramps no greater than 1:12?</u>	<u>N/A</u>
<u>Do all ramps longer than 6 feet have railings on both sides?</u>	<u>N/A</u>
<u>Are railings sturdy, and between 34 and 38 inches high?</u>	<u>N/A</u>
<u>Is the width between railings or curbs at least 38 inches?</u>	<u>N/A</u>
<u>Are ramps non-slip</u>	<u>N/A</u>
<u>Is there a 5 foot long level landing at every 30 foot horizontal length of ramp, at the top and bottom of ramps and at switchbacks?</u>	<u>N/A</u>
<u>Does the ramp rise no more than 30 inches between landings</u>	<u>N/A</u>

**ADA**  
**Self Evaluation**

**Facility:** *Wastewater Treatment Plant*

**Parking & Drop-Off**

Are an adequate number of parking spaces available?	N/A
Are 8 foot wide spaces, with minimum 8 foot wide access aisles, and 98 inches of vertical clearance, available for lift-equipped van?	N/A
Are the access aisles part of the accessible route to the accessible entrance?	N/A
Are the accessible spaces closest to the accessible entrance?	N/A
Are accessible spaces marked with the International Symbol of Accessibility?	N/A
Is there an enforcement procedure to ensure that accessible parking is used only by those who need it?	N/A

**Entrance**

If there are stairs at the main entrance, is there also a ramp or lift, or is there an alternative accessible entrance?	YES
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?	NO
Can the alternate accessible entrance be used independently?	NO
Does the entrance door have at least 32 inches clear opening?	YES
Is there at least 18 inches of clear wall space on the pull side of the door, next to handle?	YES
Is the threshold edge 1/4 inch high or less, or if beveled edge, no more than 3/4 inch high?	NO
If provided, are carpeting or mats a maximum of 1/2 inch high?	NO

**ADA**  
**Self Evaluation**

**Facility: Wastewater Treatment Plant**

<u>Is the door handle no higher than 48 inches and operable with a closed fist?</u>	<b>NO</b>
<u>Can doors be opened without too much force?</u>	<b>YES</b>
<u>If the door has a closer, does it take at least 3 seconds to close?</u>	<b>N/A</b>

**Horizontal Circulation**

<u>Does the accessible entrance provide direct access to the main floor?</u>	<b>YES</b>
<u>Are all public spaces on an accessible route of travel?</u>	<b>YES</b>
<u>Is the accessible route to all public spaces at least 36 inches wide?</u>	<b>NO</b>
<u>is there a 5 foot circle or a T-shaped space for a person using a wheelchair to reverse direction?</u>	<b>YES</b>

**Doors**

<u>Do doors into public spaces have at least a 32 inch clear opening?</u>	<b>NO</b>
<u>On the pull side of doors, next to the handle, is there at least 18 inches of ? clear wall space so that a person using a wheelchair can open the door</u>	<b>NO</b>
<u>Can doors be opened without too much force?</u>	<b>YES</b>
<u>Are door handles 48 inches high or less and operable with a closed fist?</u>	<b>NO</b>

**ADA**  
**Self Evaluation**

**Facility:** *Wastewater Treatment Plant*

**Rooms and Spaces**

Are all aisles and pathways to materials and services at least 36 inches wide? **N/A**

---

is there a 5 foot circle or T-shaped space for turning a wheelchair completely? **YES**

---

**Emergency Egress**

If emergency systems are provided, do they have both flashing lights and audible signals? **NO**

---

**Signage for Goods and Services**

If provided, do signs and room numbers designating permanent rooms and spaces where goods and services are provided comply with the appropriate requirements for such signage?

Signs mounted with centerline 60 inches from floor? **N/A**

---

Mounted on wall adjacent to latch side of door, or as close as possible **N/A**

---

Raised characters, sized between 5/8 and 2 inches high, with the high contrast? **N/A**

---

Brailled text of the same information? **N/A**

---

If pictogram is used, it must be accompanied by raised characters and braille? **N/A**

---

**ADA**  
**Self Evaluation**

**Facility:** *Wastewater Treatment Plant*

**Controls**

Are all controls that are available for use by the public located at an accessible height? **YES**

Are they opeable with a closed fist? **NO**

**Stairs**

Do treads have a non-slip surface? **N/A**

Do stairs have continuous rails on both sides, with extensions beyond the top and bottom stairs? **N/A**

**Getting to the Rest Rooms**

If rest rooms are available to the public, is at least one rest room rully accessible? **NO**

Are there signs at inaccessible rest rooms that give directions to acceisble ones? **NO**

Is there tactile signage identifying rest rooms **NO**

Are pictograms or symbols used to identify rest rooms, and, if used, are raised characters and braille included below them? **NO**

Is the doorway at least 32 inces clear? **NO**

**ADA**  
**Self Evaluation**

**Facility: Wastewater Treatment Plant**

Are doors equipped with accessible handles, 48 inches high or less? **YES**

Can doors be opened easily? **YES**

Does the entry configuration provide adequate maneuvering space for a person using a wheelchair? **NO**

Is there a 36 inch wide path to all fixtures? **Yes**

**Stalls**

Is the stall door operable with a closed fist, inside and out? **N/A**

Is there a wheelchair-accessible stall that has an area of at least 5 feet by 5 feet, clear of the door swing, OR is there a stall that is less accessible but provides greater access than a typical stall? **N/A**

In the accessible stall, are there grab bars behind and on the side wall nearest to the toilet? **N/A**

Is the toilet seat 17 to 19 inches high? **YES**

**Lavatories**

Does one lavatory have a 30 inch wide by 48 inch deep clear space in front? **NO**

Is the lavatory rim no higher than 34 inches **YES**

Is there at least 29 inches from the floor to the bottom of the lavatory apron? **YES**

Can the faucet be operated with one closed fist? **YES**

**ADA**  
**Self Evaluation**

**Facility: Wastewater Treatment Plant**

Are soap and other dispensers and hand dryers within reach ranges and usable with one closed fist? **YES**

---

Is the mirror mounted with the bottom edge of the reflecting surface 40 inches high or lower? **NO**

---

**Drinking Fountains**

is there at least one fountain with clear floor space of at least 30 by 48 inches in front? **N/A**

---

Is there one fountain with its spout no higher than 36 inches from the ground, and another with a standard height spout? **N/A**

---

Are controls mounted on the front or on the side near the front edge, and operable with one closed fist? **N/A**

---

Is each water fountain cane-detectable? **N/A**

---