

Annual Drinking Water Quality Report

IN5223005

VEEDERSBURG MUNICIPAL WATER SUPPLY

Annual Water Quality Report for the period of January 1 to December 31, 2022

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name Paul Keeling

Phone 265-294-2728

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que lo entienda bien.

VEEDERSBURG MUNICIPAL WATER SUPPLY is Ground Water

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Source Water Information

SWA = Source Water Assessment

| Source Water Name | | Type of Water | Report Status | Location |
|-------------------|---------|---------------|---------------|--------------------------|
| WELL #1 | WELL #1 | GW | <u>A</u> | <u>7th St</u> |
| WELL #3 | WELL #3 | GW | <u>A</u> | <u>7th St</u> |
| WELL #4 | WELL #4 | GW | <u>A</u> | <u>7th St</u> |

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|---|
| Copper | 08/12/2021 | 1.3 | 1.3 | 0.28 | 0 | ppm | N | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems. |
| Lead | 08/12/2021 | 0 | 15 | 4 | 1 | ppb | N | Corrosion of household plumbing systems; Erosion of natural deposits. |

Water Quality Test Results

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--|-----------------|------------------------|--------------------------|-----------------------|-----------|---------|-----------|---|
| Chlorine | 2022 | 1 | 0 - 1 | MIRDLG = 4 | MIRDL = 4 | ppm | N | Water additive used to control microbes. |
| Halooacetic Acids (HAA5) | 2022 | 9 | 9 - 9 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection. |
| Total Trihalomethanes (TTHM) | 2022 | 7 | 7 - 7 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection. |
| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Arsenic | 08/04/2020 | 0.5 | 0.5 - 0.5 | 0 | 10 | ppb | N | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes. |
| Barium | 08/04/2020 | 0.353 | 0.353 - 0.353 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Nitrate [measured as Nitrogen] | 2022 | 0.263 | 0.263 - 0.263 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits. |
| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
| Beta/photon emitters | 08/14/2017 | 4.9 | 4.9 - 4.9 | 0 | 4 | mrem/yr | N | Decay of natural and man-made deposits. |
| Combined Radium 226/228 | 08/14/2017 | 0.9 | 0.9 - 0.9 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |
| Gross alpha excluding radon and uranium | 08/04/2020 | 2.1 | 2.1 - 2.1 | 0 | 15 | pCi/L | N | Erosion of natural deposits. |
| Uranium | 08/14/2017 | 0.8622 | 0.8622 - 0.8622 | 0 | 30 | ug/l | N | Erosion of natural deposits. |

